Standard Number: 4960.17

Superseding: New

Effective Date: January 17, 2020

Page: 1 of 3

# **Key Lock Boxes**



#### 1. Scope

This standard covers the requirements for key lock boxes.

This standard applies to the following Seattle City Light (SCL) stock numbers:

Stock No.	Description
400195	Key lock box, deep
400214	Key lock box, shallow

#### 2. Application

Key lock boxes are used to store access keys to a secured building or premise. Stock No. 400195 has a 10-key capacity. Stock No. 400214 has a 2-key capacity.

## 3. Industry Standards

Key lock boxes shall meet the applicable requirements of the National Fire Protection Association (NFPA) and the following industry standards:

UL 437; Standard for Key Locks

UL 1037; Standard for Antitheft Alarms and Devices

**UL 1332**; Standard for Organic Coatings for Steel Enclosures for Outdoor Use Electrical Equipment

**UL 1610**; Standard for Central-Station Burglar-Alarm Units

Standards Coordinator Ponet Neuansourinh Standards Supervisor John Shipek Unit Director Andrew Strong

! ACSA

Superseding: New

Effective Date: January 17, 2020

Page: 2 of 3

### 4. Requirements

Key lock box requirements include:


- Surface mount type
- Stainless steel door hinge
- 1/8-inch stainless steel lock cover with tamper seal mounting capability
- 1/4-inch solid steel housing
- Solid steel door with interior gasket seal
- Dimensions per Table 4

Locks shall be UL Listed, with double-action rotating tumblers and hardened steel pins accessed by a bias-cut key.

**Table 4. Key Lock Box Dimensions** 

	Exterior Dimensions			
Stock No.	Height (in)	Width (in)	Depth (in)	Door Thickness (in)
400195	4	5	3-7/8	1/2
400214	4	5	2-3/4	1/4

Figure 4. Key Lock Box, Front View Details



#### 5. Marking

Each product shall be marked with:

- Manufacturer identification
- Manufacturer model number
- UL Listed label

## 6. Packaging

Product shall be shipped completely assembled.

Product shall be packaged to prevent damage during shipping, handling, and storage.

Standard Number: 4960.17

Seattle City Light

MATERIAL STANDARD

Key Lock Boxes

Superseding: New

Effective Date: January 17, 2020

Page: 3 of 3

Individual packages shall be legibly marked with:

- Manufacturer name
- Manufacturer catalog number
- Product description
- Seattle City Light stock number

Shipping containers shall be legibly marked with:

Seattle City Light purchase order number

#### 7. Issuance

Stock Unit: EA

## 8. Approved Manufacturers

Stock No.	Description	Manufacturer	Part No.
400195	Key lock box, deep	Knox Company	3262
400214	Key lock box, shallow	П	1658

#### 9. Sources

**Neuansourinh, Ponet**; SCL Standards Engineer and originator of 4960.17 (ponet.neuansourinh@seattle.gov)

SCL Stock Catalog page 40-2; September 15, 2017

www.knoxbox.com