
21 kV Intermediate Class, Polymer, Metal-Oxide Surge Arresters



1. Scope

This standard applies to 21 kV duty-cycle rating, intermediate class, polymer-housed, metal-oxide surge arresters.

This standard applies to SCL Stock No. 012593.

2. Application

Intermediate class surge arresters are intended for use on 26400GrdY/15240 V power systems in areas where the nominal fault duty is between 20 kA and 40 kA rms symmetrical. Arresters are installed on riser poles to protect underground cable and equipment.

In areas where the fault duty is less than 20 kA, refer to Seattle City Light (SCL) 6801.40, "21 kV, Heavy Duty Distribution Class, Polymer, Metal-Oxide Surge Arrester."

3. Industry Standards

Surge arresters shall meet the applicable requirements of the latest revision of the following standard:

IEEE C62.11, Standard for Metal-Oxide Surge Arresters for AC Power Circuits (> 1 kV)

Standard Coordinator
Muneer Shetab

Standards Engineering Supervisor
Brett Hanson

Division Director
Bob Risch

4. Electrical Requirements

Class (recognized by IEEE C62.11)	Intermediate
Type	Metal-oxide
Duty-Cycle Rating	21.0 kV rms
Maximum Continuous Operating Voltage (MCOV)	17.0 kV rms
Maximum Front-of-Wave Voltage Cresting in 0.5 Microseconds for 10 kA Wave	62.4 kV crest
Maximum Discharge Voltage for 8 X 20 Microsecond 5 kA Wave	51.7 kV crest
Maximum Discharge Voltage for 8 X 20 Microsecond 20 kA Wave	61.3 kV crest
Minimum Symmetrical RMS Fault-Current Withstand Rating	40 kA rms
Minimum Temporary Overvoltage Capability for Three Seconds at 60 Degrees Centigrade Ambient and No Prior Energy Absorption (Overvoltage/MCOV)	1.33 per unit

5. Construction

Housing Material:	Silicone rubber or equivalent silicone polymer
Housing Material/ Hanger Bracket Color:	Gray
Ground Lead Isolator	Required



Terminal – Top

Stainless steel stud with “L” bracket and eyebolt connector that accepts copper or aluminum conductors #6 AWG to 250 kcmil.

A wire-clamp terminal that accepts 6 AWG solid to 2 AWG stranded conductor is also approved.



Terminal - Bottom

3/8-16 stainless steel stud with Penn Union STS-4, Burndy KF-23, or Dossert DGG-6 connector (Stock No. 668872), or approved equivalent.

A wire-clamp terminal that accepts 6 AWG solid to 2 AWG stranded conductor is also approved.

Nameplate	Required per IEEE C62.11
------------------	--------------------------

6. Marking and Packaging

Surge arresters shall be packaged fully assembled, one per cardboard box.

Each package shall be legibly marked with:

- Manufacturer name or symbol
- Product description
- Quantity
- Seattle City Light stock number

Shipping containers shall be legibly marked with:

- Manufacturer name or symbol
- Seattle City Light purchase order number

A packing slip shall be included with each shipment.

7. Issuance

Stock Unit: EA

8. Approved Manufacturers

Approved Manufacturer	Catalog No.
Hubbell Power Systems, Inc.	218417-7214
MacLean Power Systems	ZIP0021-D005

9. Sources

Shetab, Muneer; SCL Standards Engineer and subject matter expert for 6801.60

Shipek, John; SCL Standards Supervisor and subject matter expert for 6801.60

Hubbell Power Systems Inc., Arresters, IEEE & IEC Distribution Class, Catalog 70,
April 2004

MacLean Power Systems Inc., ZIP Intermediate Class Surge Arresters,
Catalog AR-19, May 2010