Standard Number: 7080.09

Superseding: New

Effective Date: April 16, 2020 Page: 1 of 3

# Fittings, Liquidtight, Metallic



## 1. Scope

This standard covers the requirements for fittings used with liquidtight flexible metallic (LFMC) and nonmetallic (LFNC) conduit.

This material standard applies to the following Seattle City Light (SCL) stock numbers:

Stock No.	Type	Trade Size (in)
012088	Straight	1/2
012089	Straight	3/4
012090	90 degree	1/2
012091	90 degree	3/4

## 2. Application

Fittings are used with LFMC and LFNC installed in outdoor or indoor locations where exposed to continuous or intermittent moisture.

## 3. Industry Standards

Fittings shall meet the applicable requirements of the latest revision of the following industry standards:

**NEMA FB 1**; "Fittings, Cast Metal Boxes, and Conduit Bodies for Conduit, Electrical Metallic Tubing, and Cable"

**UL 514B**; "Conduit, Tubing, and Cable Fittings"

#### 4. Requirements

Fittings shall have the features listed in Sections 4.1 and 4.2.

Standards Coordinator Muneer Shetab Standards Supervisor John Shipek

Man La Stehl Goldfiel

Unit Director Andrew Strong

ACH

Page: 2 of 3

Superseding: New Effective Date: April 16, 2020

#### 4.1 Straight Connectors

Straight connectors shall have the following attributes:

- Steel, zinc die-cast, malleable iron, zinc electroplate construction
- 105-degree C-rated thermoplastic insulator
- Suitable for use with LFMC and LFNC

Figure 4.1. Straight Connector



## 4.2 Angled Connectors, 90-Degree

Angled connectors shall have the following attributes:

- Steel, zinc die-cast, malleable iron, zinc electroplate construction
- 105-degree C-rated thermoplastic insulator
- Suitable for use with LFMC and LFNC

Figure 4.2. Angled Connector



## 5. Packaging

Fittings shall be packaged to prevent damage during shipping, handling, and storage.

Each standard package shall be legibly marked with the following information:

- Manufacturer identification
- Product description
- SCL stock number
- Quantity

Each shipping container shall be legibly marked with the following information:

SCL purchase order number

#### 6. Issuance

Stock Unit: EA

Standard Number: 7080.09

Seattle City Light MATERIAL / CONSTRUCTION STANDARD / WORK PRACTICE Fittings, Liquidtight, Metallic

Superseding: New Effective Date: April 16, 2020

Page: 3 of 3

## 7. Approved Manufacturers

					Cooper		Steel Electric
	Trade		T&B	Bridgeport	Crouse-Hinds	RACO-Hubbell	Supply Co.
Stock No.	Size (in)	Type	Part No.	Part No.	Part No.	Part. No.	Part No.
012088	1/2	Straight	5332	430-SLTI	LTB50*	3512RAC*	SLT27T
012089	3/4	Straight	5333	431-SLTI	LTB75*	3513RAC*	SLT28T
012090	1/2	90-degree	5352	470-LT2*	LTB5090*	3542*	SLT35T
012091	3/4	90-degree	5353	471-LT2*	LTB7590*	3543*	SLT36T

Note: LFMC connectors that can also be used with LFNC are marked with an asterisk (\*).

#### 8. Sources

**Shetab, Muneer**; SCL Standards Engineer, originator, and subject matter expert for 7080.09 (muneer.shetab@seattle.gov)

SCL Stock Catalog Page 73-8, June 30, 2017

www.tnb.com

www.bpfittings.com

www.cooperindustries.com

www.hubbell.com

www.sepco-usa.com