

Vibration Damper Pads



1. Scope

This standard covers the requirements for vibration damper pads.
This standard applies to Seattle City Light (SCL) Stock No. 727716.

2. Application

Vibration dampers, which are also referred to as elastomeric pad-type isolators, provide excellent high frequency sound attenuation when used directly under HVAC, power generation and electrical equipment. The recommended loading is 5 – 60 psi.

3. Requirements

Vibration damper pads shall be elastomeric and have the dimensions of 1" x 36" x 36".

4. Packaging

Vibration damper pads shall be packaged to prevent damage during shipping, handling, and storage.

The package shall be legibly marked with:

- Manufacturer name
- Manufacturer part number
- Product description
- SCL stock number

Shipping containers shall be legibly marked with:

- SCL purchase order number

5. Issuance

Stock Unit: SH

6. Approved Manufacturer

Manufacturer	Catalog No.
VMC/Amber/Booth	AMPAD NRC 1X36X36

7. Sources

SCL Stock Catalog page 72-18; February 19, 2010

Lu, Curtis; SCL Standards Engineer and originator of 7276.85

<https://thevmcgroup.com>