Standard Number: **7365.08**

Superseding: New

Effective Date: June 19, 2020

Page: 1 of 2

Duct Tape, Cloth, Waterproof



1. Scope

This standard covers the requirements for waterproof cloth duct tape.

This standard applies to Seattle City Light (SCL) Stock No. 736745.

Application

Duct tape is used to seal polychlorinated biphenyl (PCB) and asbestos suits and plastic sheets. Suitable for use on rough surfaces such as wood, metal, and concrete.

Industry Standards

Duct tape shall meet the applicable requirements of the latest revision of the following industry standards:

UL 723; Standard for Test for Surface Burning Characteristics of Building Materials

ASTM E84; Standard Test Method for Surface Burning Characteristics of Building Materials

Standards Coordinator Muneer Shetab

Standards Supervisor John Shipek

Unit Director Andrew Strong

Man 6 Stell Goldfiel

Standard Number: **7365.08**

Seattle City Light

MATERIAL STANDARD

Duct Tape, Cloth, Waterproof

Superseding: New

Effective Date: June 19, 2020

Page: 2 of 2

4. Requirements

Duct tape shall have the following requirements:

| Description | Requirement |
|--|--|
| Length per roll (yd) | 60 |
| Width, nominal (in) | 1.89 |
| Thickness, nominal (mils) | 10 |
| Adhesive | Rubber |
| Carrier/backing | Polyethylene (PE) coated cloth, waterproof |
| Color | Gray or silver |
| Adhesion, min (oz/in) | 51 (to stainless steel test panel) |
| Tensile strength, min (lb/in) | 34 |
| Service/operating temperature range (°F) | 40–200 |

5. Packaging

Duct tape shall be packaged to prevent damage during shipping, handling, and storage.

Each standard package shall be legibly marked with the following information:

- Manufacturer identification
- Product description
- SCL stock number
- Quantity

Each shipping container shall be legibly marked with the following information:

SCL purchase order number

6. Issuance

Stock Unit: RL

7. Approved Manufacturers

| Stock No. | 3M Part No. | Nashua Part No. |
|-----------|-------------|-----------------|
| 736745 | 6969 | 357 |

8. Sources

www.redgreen.com

Shetab, Muneer; SCL Standards Engineer, originator, and subject matter expert for 7365.08 (muneer.shetab@seattle.gov)

Stock Catalog Page, 73-40, January 11, 2014