

**Protectors, Leather,
for Class 2 Rubber Insulating Gloves**



1. Scope

This material standard covers the requirements for leather protector gloves appropriate for use with Class 2 electrical insulating rubber gloves, Material Standard 7634.62.

The requirements for leather protector gloves appropriate for use with Class 0 electrical insulating rubber gloves are specified in Material Standard 7634.20.

This material standard applies to the following Seattle City Light stock numbers:

Stock Number	Size
763353	8
763350	8-1/2
763354	9
763351	9-1/2
763355	10
763352	10-1/2
763356	11
763357	12

2. Application

Leather protector gloves, also known as keepers, are worn over rubber insulating gloves to protect against cuts, abrasions, and punctures.

Rubber insulating gloves shall not be used without leather protector gloves.

Leather protector gloves shall not be used alone for protection against electric shock.

3. Industry Standards

Gloves shall meet the requirements of the following industry standard:

ASTM F 696-06 - Standard Specification for Leather Protectors for Rubber Insulating Gloves and Mittens

4. Detailed Requirements

Leather protector gloves shall have the following attributes:

length	12 inches
glove color	may vary from cream to tan
cuff design	straight
cuff color (backside)	fluorescent orange
type	cowhide
required options	non-metallic buckle and pull strap

5. Marking

Each glove shall be marked according to the requirements of ASTM F-696, Section 9.

6. Testing

Gloves shall be tested according to the requirements of ASTM F-696, Section 8.

Test data that establishes compliance with the requirements of ASTM F-696 shall be provided upon request.

7. Packaging

Gloves shall be packaged to keep them clean during shipping and storage.

8. Issuance

PR

9. References

7634.20; "Protectors, Leather, for Class 0 Rubber Insulating Gloves;" Material Standard; SCL

7634.61; "Gloves, Insulating, Rubber, Class 1;" Material Standard; SCL

7634.62; "Gloves, Insulating, Rubber, Class 2;" Material Standard; SCL

D 120-08; "Standard Specification for Rubber Insulating Gloves"; ASTM

F 496-08; "Standard Specification for In-Service Care of Insulating Gloves and Sleeves"; ASTM

Shipek, John; SCL Standards Engineer, subject matter expert and originator of 7634.21 (john.shipek@seattle.gov)

10. Approved Manufacturers

Stock Number	Size	Edwards Glove Company	Kunz Glove Company	Salisbury
763353	8	303B-8	1050-3*8	LP3S/8
763350	8-1/2	303B-8.5	1050-3*8.5	LP3S/8H
763354	9	303B-9	1050-3*9	LP3S/9
763351	9-1/2	303B-9.5	1050-3*9.5	LP3S/9H
763355	10	303B-10	1050-3*10	LP3S/10
763352	10-1/2	303B-10.5	1050-3*10.5	LP3S/10H
763356	11	303B-11	1050-3*11	LP3S/11
763357	12	303B-12	1050-3*12	LP3S/12