
Fuse Pullers, 7-1/2 in, Pocket Size



1. Scope

This standard covers the requirements for pocket size fuse pullers.

This standard applies to the Seattle City Light (SCL) Stock No. 764807.

2. Application

Fuse pullers are used to pull 1/2-inch to 1-inch diameter fuses.

3. Requirements

Fuse pullers shall:

- Be suitable for removing cartridge-type fuses, up to 600 V rated, 1/2-inch to 1-inch in diameter
- Be constructed of fully insulated material
- Have a no-slip grip handle

4. Packaging

Fuse pullers shall be individually packaged and marked with:

- Manufacturer name
- Product description
- Seattle City Light stock number

Shipping containers shall be legibly marked with:

- Manufacturer name
- Product description

5. Issuance

Stock Unit: EA

Standards Coordinator
Ponet Neuansourinh

Standards Supervisor
John Shipek

Unit Director
Andrew Strong



6. Approved Manufacturers

Description	Manufacturer	Product No.
Fuse puller, 7-1/2"	Ideal	34-002

7. Sources

Neuansourinh, Ponet; SCL Standards Engineer and originator of 7659.40
(ponet.neuansourinh@seattle.gov)

SCL Stock Catalog page 76-19; October 6, 2017

www.idealindustries.ca