

Anchors, Nail Drive



1. Scope

This standard covers the requirements for nail drive anchors.

This standard applies to the following Seattle City Light (SCL) stock numbers:

Stock No.	Description, d x l (in)
780010	1/4 x 1
010335	1/4 x 1-1/2

2. Application

Nail drive anchors are used to fasten signage to concrete, brick masonry, and stone.

Product installation requires a 1/4 in drill bit. Refer to manufacturer's literature for complete instructions and performance data.

Nail drive anchors should not be used for overhead, life-safety or sustained tensile loading.

3. Requirements

Anchor body shall be corrosion-resistant, Zamac Nailin with mushroom head.

Drive nail shall be carbon steel.

Standards Coordinator
John Shipek



Standards Supervisor
John Shipek



Unit Director
Darnell Cola



4. Packaging

Product shall be packaged to prevent damage during shipping, handling, and storage.

Product shall be packaged 100 to a box.

Individual packages shall be legibly marked with:

- Manufacturer name
- Manufacturer catalog number
- Product description

Shipping container shall be legibly marked with:

- SCL purchase order number
 - SCL stock number
-

5. Issuance

Stock Unit: EA

6. Approved Manufacturers

Stock No.	Description, d x l (in)	Manufacturer	Catalog No.
780010	1/4 x 1	Powers Fastening Innovations	Zamac Nailin 2808
010335	1/4 x 1-1/2	Powers Fastening Innovations	Zamac Nailin 2820

7. Sources

SCL Stock Catalog page 78-4; October 19, 2005

Shipek, John; SCL Standards Supervisor and originator of 7800.72

Tech Manual – Mechanical Anchors 2017 Powers, Rev. D

www.powers.com