

BRACE, CROSSARM




Figure 1, Flat Crossarm Brace 1/4" x 1-1/4"




Figure 2, Angle Crossarm Brace 3/16" x 1-3/4" x 1-3/4"

1. **Flat Crossarm Braces.** Figure 1, shall be fabricated from hot-rolled bar steel, in accordance with EEI TDJ-6, except as modified herein (9/16" holes at both ends).
2. **Angle Crossarm Braces** shall be of the configuration shown in Figure 2, fabricated from one piece of structural steel, in accordance with EEI TDJ-6, as it applies to angle crossarm braces.
3. **Flat and Angle Crossarm Braces** shall be hot-dipped galvanized after fabrication per ASTM A 153 (3 mils minimum).
4. **Packaging** shall be in accordance with EEI Packaging Standards.
5. **Reference Specifications:** EEI TDJ-6; ASTM A 153
6. **Stock Unit:** EA

Approved Manufacturers

Stock Number	Figure	Approved Manufacturers			
		Chance	Cooper	Joslyn	Village Ironworks
563005	1	T203-0463	-	-	AB-32-WI
563010	2	-	DB2L3	J-1512	-

STANDARDS COORDINATOR

Charles L. Shaffer

STANDARDS SUPERVISOR

John Chinner

UNIT DIRECTOR

Hardee Juy