

Conduit, Rigid Aluminum

- 1. Scope:** This specification covers rigid aluminum conduit. Conduit shall comply with the requirements of ANSI Standard Specification C80.5 for Rigid Aluminum Conduit and Underwriters' Laboratories, Inc. Standard UL6 for Rigid Metallic Conduit.
- 2. Identification:** Each length of conduit shall be identified with the manufacturer's name or trademark, UL label, and the words "Rigid Aluminum Conduit" or "Rigid Metal Conduit."
- 3. Couplings:** Each 10-foot length of conduit shall be furnished with a coupling attached to one end, and the other threaded end shall be protected by a suitable cover.
- 4. Packaging:** Conduit shall be packaged in accordance with the manufacturer's commercial practice to ensure safe delivery without damage.
- 5. Inspection and Test:** Conduit may be subject to test and inspection under the provisions of ANSI C80 or UL6. The supplier shall, at his own expense, replace any rejected conduit.

6. Rigid Aluminum Conduit

Stock Unit: FT

Stock No.	Nominal Pipe Size, in.
734752	3/4
734754	1-1/4



In October 2015, this standard was renumbered from 7343.5 to 7040.05.

Standards Coordinator
John Shipek

Standards Supervisor
John Shipek

Unit Director
Andrew Strong