

Straps, Stamped Steel, One-Hole



1. Scope

This standard covers the requirements for one-hole, stamped steel straps.

This material standard applies to the following Seattle City Light (SCL) stock numbers:

Stock No.	Trade Size (in)
731418	1/2
731419	3/4
731420	1

2. Application

Straps are used to support electrical metallic tubing (EMT) conduit.

3. Requirements

Straps shall have the following attributes:

- Stamped steel construction
- Zinc-electroplate
- One-hole
- Mounting bolt size, 1/4 in

4. Packaging

Straps shall be packaged to prevent damage during shipping, handling, and storage.

Each standard package shall be legibly marked with the following information:

- Manufacturer identification
- Product description
- SCL stock number
- Quantity contained

Muneer Shetab *John Shipek*

Andrew Strong

Each shipping container shall be legibly marked with the following information:

- SCL purchase order number
-

5. Issuance

Stock Unit: EA

6. Approved Manufacturers

Stock No.	Trade Size (in)	Bridgeport Fittings	Emerson/O-Z/ Gedney	Hubbell/ RACO	ABB/ Steel City	ABB/ Thomas & Betts
731418	1/2	920-S	15-50S	2082	TS-101	4159
731419	3/4	921-S	15-75S	2083	TS-102	4160
731420	1	922-S	15-100S	2084	TS-103	4161

7. Sources

www.tnb.com

www.bpfittings.com

www.o-zgedney.com

www.hubbell.com

Shetab, Muneer; SCL Standards Engineer, originator, and subject matter expert for 7134.55

Stock Catalog Page 73-12; October 30, 2013