

Concrete Building Bricks



1. Scope

This standard covers the requirements for concrete building bricks.
This standard applies to Seattle City Light (SCL) Stock No. 720130.

2. Application

Concrete building bricks are used to raise sump pumps off floor and to adjust elevation of hatch frames on vaults.

3. Industry Standards

Concrete building bricks shall be manufactured to meet the requirements of the latest revision of the following industry standards: ASTM C55, Standard Specification for Concrete Building Brick.

4. Requirements

Concrete building bricks shall be gray in color, with nominal dimensions of 4 inches by 2-1/4 inches by 8 inches.

5. Packaging

Bricks shall be packaged on pallets and wrapped to prevent damage during shipping, handling, and storage. The package shall be legibly marked with:

- Manufacturer name
- Manufacturer part number
- Product description
- SCL stock number



Shipping containers shall be legibly marked with:

- SCL purchase order number
-

6. Issuance

Stock Unit: EA

7. Approved Manufacturers

Manufacturer Name	Description	Item No.
Basalite	428 HW Concrete Brick Natural	100015626

8. Sources

Lu, Curtis; SCL Standards engineer and originator of 7392.84 (curtis.lu@seattle.gov)

SCL Stock Catalog page 70-33; May 10, 2016

www.basalite.com