

Liners, Glove, FR, Fleece



1. Scope

This standard covers the requirements for fleece, FR glove liners.

This standard applies to the following Seattle City Light (SCL) stock numbers:

Stock No.	Description
014819	Small
014820	Medium
014821	Large
014822	XL
014823	2XL

2. Application

Fleece FR glove liners are for use under leather ground gloves during freezing or snowy weather conditions to keep hands warm and dry.

3. Industry Standards

Liners shall meet the applicable requirements of the most recent revision of the following industry standards:

ASTM D6413; "Standard Test Method Flame Resistance of Textiles (Vertical Test)"

ASTM F2675/F267M-13; Standard Test Method for determining Arc Ratings of Hand Protective Products Developed and Used for Electrical Arc Flash Protection

Standard Coordinator
Laura Vanderpool



Standards Engineering Supervisor
John Shipek



Division Director
Tamara Jenkins



4. Requirements

Liners shall be:

- Made of Polartec Power Dry FR microfleece
 - Permanently flame resistant
 - Arc flash rated at 9.5 cal/cm²
-

5. Packaging

Each standard package shall be legibly marked with the following information:

- Manufacturer identification
- Product description and size
- SCL stock number

Each shipping container shall be legibly marked with the following information:

- Manufacturer identification
 - SCL purchase order number
-

6. Issuance:

Stock unit: PR

7. Approved Manufacturers

Stock No.	Size	Youngstown Glove Company Catalog No.
014819	Small	12-3565-60-S
014820	Medium	12-3565-60-M
014821	Large	12-3565-60-L
014822	XL	12-3565-60-XL
014823	2XL	12-3565-60-XXL

8. Sources

Vanderpool, Laura; Standards Engineering Technical Writer and subject matter expert for 4010.33

www.ytgloves.com