



**CONDUCTOR FITTINGS, COPPER
PARALLEL TAP, SPLIT BOLT CABLE CONNECTORS**



6688-7.tif



1. Scope

Parallel tap, split bolt connectors shall be of the configuration shown. The body, nut and retainer shall be manufactured from high-strength bronze alloys. The retainer must be V-grooved or have a serrated contact face.

2. Stock Unit: EA

3. Approved Manufacturers

Stock No.	Maximum Copper Conductor		Approved Manufacturers					
	Solid	Stranded	Anderson	Blackburn	Burndy	Dossert	Homac	IlSCO
668860	#10	#12	C10	9H	KS90	DS09	E10	IK-10
668861	8	8	SBN8	8H	KS15	DS1	E8	IK-8
668862	6	7	SBN6	6H	KS17	DS2	E6	IK-6

4. Sources

SCL Material Standard 6600.0; "Connectors, Electrical, Wire and Cable, Copper Alloy, Pressure" (canceled)

Standard Coordinator
Brett Hanson

Standards Engineering Supervisor
John Shipek

Division Director
Andrew Strong