


## Spill Supplies, Neutralizing Sorbent, Acid/Base, Granular



### 1. Scope

This standard covers the requirements for granular, acid/base neutralizing sorbent. This standard applies to Seattle City Light (SCL) Stock No. 756104.

### 2. Application

Granular, acid/base neutralizing sorbent is an amphoteric (a compound that can react both as a base and as an acid) spill-response product that neutralizes acids and bases when applied to potentially environmentally hazardous materials involved in a spill.

The amount of Amphomag needed to contain an aqueous spill is about the weight of the spill. In order to completely neutralize the spill material, the amount of Amphomag required will depend on the concentration of the spilled substance.

Amphomag has a long shelf life as long as the product remains in the original factory-sealed container and is stored in a cool, dry place. The manufacturer recommends inspection of the product every six months. If the product is clumped or a color change is observed, then it should be replaced.

### 3. Requirements

The neutralizing sorbent shall have the following attributes:

- Be designed to change colors, red for acid, blue for base, and yellow/green for when spilled material has been neutralized
- Non-toxic
- Dispenser style: shaker bottle for easy dispensing

Standard Coordinator  
Laura Vanderpool

Standards Engineering Supervisor  
John Shipek

Division Director  
Tamara Jenkins

#### 4. Packaging

Product shall be packaged to prevent damage during shipping, handling, and inside storage.

- Individual packages shall be legibly marked with:
- Manufacturer name
- Manufacturer catalog number
- Product description
- SCL stock number

Shipping containers shall be legibly marked with:

- SCL purchase order number

---

#### 5. Issuance

Stock unit: EA

---

#### 6. Approved Manufacturers

Premier Magnesia, LLC

---

#### 7. Sources

**SCL Stock Catalog page 76-13**; September 29, 2017

**Vanderpool, Laura**; SCL Standards Technical Writer, originator, and subject matter expert for 7610.26

**[www.amphomag.com](http://www.amphomag.com)**