

## Pull Tape, Polyester



### 1. Scope

This standard covers the requirements for polyester pull tape, also known as mule tape.

This standard applies to the following Seattle City Light (SCL) stock numbers:

Stock No	Length per Reel (ft)
012293	400, minimum
012480	3000

### 2. Application

Pull tape is used to initiate cable pulling in underground conduit systems.

### 3. Industry Standards

Pull tape shall meet the applicable requirements of the latest revision of the following industry standard:

**GR-356-CORE**; Generic Requirements for Optical Cable Innerduct, Associated Conduit, and Accessories

### 4. Requirements

Pull tape shall have the following attributes:

- Polyester
- Woven construction
- Silicone lubricated
- Printed with sequential footage markings
- Splice free

Standards Coordinator  
Muneer Shetab

Standards Supervisor  
John Shipek

Unit Director  
Andrew Strong

*Muneer Shetab* *John Shipek*

*Andrew Strong*

**Table 4. Polyester Pull Tape Requirements**

Stock No.	Tensile Strength (lb)	Approximate Width (in)	Length Per Reel (ft)
012293	2500	3/4	400 or 500
012480	2500	3/4	3000


**5. Packaging**

Pull tape shall be packaged to prevent damage during shipping, handling, and storage. Reels shall be made of non-returnable plastic and have the dimensions shown in Table 5.

**Table 5. Reel Dimensions (in), Nominal**

Stock No.	Flange Dia. (A)	Traverse (B)	Drum Dia. (C)
012293	12	6	3-1/2
012480	13	10-1/2	3-1/2

**Figure 5. Reel Dimensions**



Each standard package shall be legibly marked with the following information:

- Manufacturer's identification
- Product description
- SCL stock number
- Quantity

Each shipping container shall be legibly marked with the following information:

- SCL purchase order number

**6. Issuance**

Stock Unit: FT

---

**7. Approved Manufacturers**

<b>Stock No.</b>	<b>Length Per Reel (ft)</b>	<b>Fibertek</b>	<b>Pacific Strapping Inc. (Herculine)</b>	<b>Neptco</b>
012293	400, minimum	WP2500-400	P2500W-400	WP2500P-500
012480	3000	WP2500-3000	P2500W-3000	WP2500P-3000

---

**8. Sources**

[www.fibertekinc.com](http://www.fibertekinc.com)

[www.neptco.com](http://www.neptco.com)

[www.pacstrap.com](http://www.pacstrap.com)

**Shetab, Muneer**; SCL Standards Engineer, originator, and subject matter expert for 7645.30 (muneer.shetab@seattle.gov)

**Stock Catalog Page 73-78**, June 11, 2018